



Supplemental/ Bid Bulletin No. 3
28 October 2019

PUBLIC BIDDING No. 19 – 308 – 4
Design and Build of Electrical Substation and Distribution System for the
Philippine Navy (PN)

Issued pursuant to Sec. 22.5 of the IRR of R.A. 9184 to clarify and/or amend certain provisions in the Bidding Documents issued for this project, considering the issues raised and clarifications made by prospective bidders thru written queries received within the prescriptive period for filing.

I. Clarifications/Recommendations

No.	REFERENCE	RESPONSE
<i>SMART-TECH ELECTRO-INDUSTRIAL SYSTEMS, INC.</i>		
1	I would like to ask for the finished elevation of the power substation from the ground. Because, the elevation was not indicated in the construction plans.	<i>It is the design of the proponent which will determine the elevation of the power substation and distribution system as the project is Design and Build.</i>
2	We would like to asked, who will do the termination/interconnection of the new substation to the existing 69KV transmission line. Since, this scope is not mentioned whatsoever in the scope of works.	<i>The Contractor will terminate/interconnect the new substation to the existing 69KV transmission line in close coordination with the local electric cooperative. Any works and materials that would be required to ensure that the substation will operate safely are to be shouldered by the Contractor.</i>
3	For the interest of the Philippine Government and of the end user as well. I would like to recommend that the term "TYPE TESTED" be added to the technical specifications of all high voltage switchgears & power Circuit breakers. Type tested essentially means that the switchgears, power circuit breakers & Panel Boards runs and passed through a series of tests in compliance with the international electrical industry standards.	<i>Agree. The End-User requires that all equipment/parts to be delivered for the project has passed the Standards, Factory Actual Test, Testing, Commissioning and extension of manufacturer's warranty for one year.</i>

The herein amendments form an integral part of the bidding documents. Correspondingly, all other provisions in the bidding documents affected by these amendments are similarly amended or modified.

The clarifications made, explain in greater detail the purpose or intent of the requirement and do not necessarily amend that particular provision in the bidding documents.

(SGD.)
ENGR. ESTRELLITA G. FULE
Chairperson, DBM-PS BAC IV