



Bid Bulletin No. 4
30 July 2021

PUBLIC BIDDING No. 21-098-10

***Supply, Delivery and Installation of Various Airconditioning Units
 for the Bureau of Immigration***

Issued pursuant to Sec. 22.5 of the IRR of R.A. 9184 to clarify and/or amend certain provisions in the Bidding Documents issued for this project, considering the issues raised and clarifications made by prospective bidders during the Pre-Bid Conference held on **July 16, 2021** likewise, respond to bidders' written queries received within the prescriptive period for filing.

A. AMENDMENTS

REFERENCE			JUSTIFICATION/ EXPLANATION
<i>SECTION VI. SCHEDULE OF REQUIREMENTS</i>			
Page 29 XXX Delivery Period Within Sixty (60) Ninety (90) Calendar Days from the receipt date indicated in the Notice to Proceed (NTP) XXX			<p><i>To amend the delivery period.</i></p> <p><i>Please refer to the "Annex A" for the amended form.</i></p>
<i>SECTION VII. TECHNICAL SPECIFICATIONS</i>			
Page 39 XXX			<p><i>To amend the requirements.</i></p> <p><i>Please refer to the "Annex B" for the amended form.</i></p>
ITEM NO.	ITEM	DESCRIPTION	
1	Aircon Floor Mounted 5 Tonner Inverter (with Installation) <i>Conforms to the minimum</i>	Type of Compressor: Scroll / Rotary	

	<i>specifications unless specified</i> Brand: _____ Model: _____		
ITEM NO.	ITEM	DESCRIPTION	
2	Aircon Floor Mounted 3 Tonner Inverter (with Installation) <i>Conforms to the minimum specifications unless specified</i> Brand: _____ Model: _____	Cooling Capacity: 25,000-40,000 BTU/h <u>38,000 BTU/h</u> <u>(minimum) or higher</u> Noise Level (Indoor): 43-57db <u>43-58db</u>	
ITEM NO.	ITEM	DESCRIPTION	
3	Aircon Ceiling Mounted 3 Tonner Inverter (with Installation) <i>Conforms to the minimum specifications unless specified</i> Brand: _____ Model: _____	Cooling Capacity: 18,000-38,000 BTU/h <u>15,000 BTU/h</u> <u>(minimum) or higher</u>	
XXX			

B. CLARIFICATIONS

No.	CONCERN	REFERENCE	CLARIFICATION/ RESOLUTION
1.	The prospective bidder requesting for the delivery period from 60 days to be 120 days because of the provincial location.	Section VI: Schedule of Requirements	<i>Please refer to the above amendment.</i>

2.	The prospective bidder offering a single phase for 5TR Floor Mounted Inverter.		<i>Original requirement is retained.</i>
3.	The prospective bidder clarifies the pipe length for the Bureau of Immigration Office	Section VII. Technical Specifications	<ul style="list-style-type: none"> • <i>Floor Mounted 5TR – 25-30 ft.</i> • <i>Floor Mounted 3TR – 40 ft.</i> • <i>Wall Mounted 2HP – 40-50 ft.</i> • <i>Ceiling Mounted 3TR – 30-40 ft.</i>
4.	The prospective bidder wants to confirm if there is an existing power supply.	Section VII. Technical Specifications	<i>Yes, there is an existing power supply</i>
5.	<p>The prospective bidder would like to clarify the following statement to be considered and included.</p> <ul style="list-style-type: none"> • Item No. 1 – Aircon Floor Mounted 5 Tonner inverter <p>Type of Compressor : Scroll / Rotary</p> <ul style="list-style-type: none"> • Item No. 2 - – Aircon Floor Mounted 3 Tonner inverter <p>Cooling Capacity – 25,000 – 38,000 BTU/h</p> <p>Noise Level (Indoor) – 48-58 db</p> <ul style="list-style-type: none"> • Item No. 4 – Aircon Wall Mounted 2HP 	Section VII. Technical Specifications	<i>Please refer to the above amendment.</i>

	Cooling Capacity – 9,103 – 20,472 BTU/Hr		
6.	The prospective bidder requesting for the delivery period from 60 days to be 90 days because of the provincial location.	Section VI: Schedule of Requirements	<i>Please refer to the above amendment.</i>
7.	The prospective bidder requesting for the Delivery address of the 50 units 2.0 HP Window Type.	Section VI: Schedule of Requirements	<i>Delivery address is Room 101 Property Section, Bureau of Immigration, Magallanes Drive, Intramuros, Manila</i>
8.	The prospective bidder clarifies for the feeder line. Is this including on the bidders scope of works or Bureau of Immigration will provide from their supply?	Section VII. Technical Specifications	<i>The feeder line will be included on the bidder Installation scope of work.</i>

All other portions of the Bidding Documents affected by these amendments shall be made to conform to the same.

Amendments/inclusions/clarifications made herein shall be considered an integral part of the Bidding Documents.

The changes made in the Philippine Bidding Documents (6th Edition, July 2020) are deemed integrated in the terms and conditions for this project.

SIGNATURE REDACTED

ENGR. JAIME M. NAVARRETE, JR.
Chairperson, Bids and Awards Committee X

For the purpose of this Bulletin and for better understanding of its contents, the following rules shall apply: (a) Double Strike out – denotes deletion; (b) Underline – denotes inclusion or new item/requirement; and "xxx" – denotes separation of phrase/s being amended from the rest of the main text.

Section VI. Schedule of Requirements

Lot No.	Qty	Item/Description	Delivery period
1	1 Lot	Supply, Delivery and Installation of Various Air-conditioning Units for the Bureau of Immigration	<p style="text-align: center;">Within Ninety (90) Calendar Days from the receipt date indicated in the Notice to Proceed (NTP)</p> <p>Note: Presence of the winning bidder's authorized representative is required during the delivery at the project site.</p>

I hereby commit to deliver the required quality and quantities upon receipt of the Purchase Order as indicated above.

Name of Company

Signature Over Printed
Name of Authorized
Representative

Date

Item/
Description: **Supply, Delivery and Installation of Various Airconditioning**
Quantity: **Units for the Bureau of Immigration**
One (1) Lot

ITEM NO.	ITEM	DESCRIPTION	QTY	BIDDERS STATEMENT OF COMPLIANCE ¹
1	Aircon Floor Mounted 5 Tonner Inverter (with Installation) <i>Conforms to the minimum specifications unless specified</i> Brand: _____ Model: _____	Indoor Unit Energy Efficiency Ratio: 11 (minimum) Cooling Capacity: 25,000-60,000 BTU/h Power Supply (Voltz/Hertz/Phase): 220-240/50-60/3 Noise Level (Indoor): 43-57db Refrigerant: R410A / R32 Features: Manufacturer's Standard Outdoor Unit Type: Air Cooled Power Supply (Voltz/Phase/Hertz): 220-240/3/60 System Power Input: 5,100 watts Type of Compressor: Scroll / Rotary Support Bracket: Durable Circuit Breaker: 3 phase	18 units	

¹ [Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the applicable laws and issuances.]

		<p>Features: Manufacturer's Standard</p> <p>Warranty:</p> <p>Labor and Parts (1 year)</p> <p>Compressor (5 years)</p> <p>Warranty and Services:</p> <p>The winning bidder shall provide free parts, maintenance and services during the first year or operations, five (5) years warranty shall be provided for the compressor upon delivery and duly inspected. Replacement of unit is necessary if found defective.</p>		
2	<p>Aircon Floor Mounted</p> <p>3 Tonner Inverter (with Installation)</p> <p><i>Conforms to the minimum specifications unless specified</i></p> <p>Brand: _____</p> <p>Model: _____</p>	<p>Energy Efficiency Ratio: 10 (minimum)</p> <p>Cooling Capacity: 38,000 BTU/h (minimum) or higher</p> <p>Power Supply (Voltz/Hertz/Phase): 220-240/50-60/1</p> <p>Compressor: Rotary</p> <p>Refrigerant: R410A / R32</p> <p>Noise Level (Indoor): 43-58db</p> <p>Features: Manufacturer's Standard</p> <p>Warranty:</p> <p>Labor and Parts (1 year)</p> <p>Compressor (5 years)</p> <p>Warranty and Services:</p> <p>The winning bidder shall provide free parts, maintenance and services during the first year or operations, five (5) years warranty shall be provided for the compressor upon delivery and duly inspected. Replacement of unit is necessary if found defective.</p>	35 units	

3	<p>Aircon Ceiling Mounted</p> <p>3 Tonner Inverter</p> <p>(with Installation)</p> <p><i>Conforms to the minimum specifications unless specified</i></p> <p>Brand: _____</p> <p>Model: _____</p>	<p>Energy Efficiency Ratio: 9.6-17.3 KJ/W-Hr</p> <p>Cooling Capacity: 15,000 BTU/h (minimum) or higher</p> <p>Power Supply (Voltz/Hertz/Phase): 220-240/60/1</p> <p>Features: Manufacturer's Standard</p> <p>Warranty:</p> <p>Labor and Parts (1 year)</p> <p>Compressor (5 years)</p> <p>Warranty and Services:</p> <p>The winning bidder shall provide free parts, maintenance and services during the first year or operations, five (5) years warranty shall be provided for the compressor upon delivery and duly inspected. Replacement of unit is necessary if found defective.</p>	25 units	
4	<p>Aircon Wall Mounted</p> <p>2HP</p> <p>(with Installation)</p> <p><i>Conforms to the minimum specifications unless specified</i></p> <p>Brand: _____</p> <p>Model: _____</p>	<p>Energy Efficiency Ratio: 11 (minimum)</p> <p>Cooling Capacity: 15,000-22,200 BTU/h</p> <p>Power Supply (Voltz/Hertz/Phase): 220-230/60/1</p> <p>Refrigerant: R410A / R32</p> <p>Warranty:</p> <p>Labor and Parts (1 year)</p> <p>Compressor (5 years)</p> <p>Warranty and Services:</p> <p>The winning bidder shall provide free parts, maintenance and services during the first year or operations, five (5) years warranty shall be provided for the compressor upon delivery and duly inspected. Replacement of unit is necessary if found defective.</p>	40 units	

5	<p>Aircon Window Type</p> <p>2HP Inverter</p> <p>(no Installation)</p> <p><i>Conforms to the minimum specifications unless specified</i></p> <p>Brand: _____</p> <p>Model: _____</p>	<p>Energy Efficiency Ratio: 10 (minimum)</p> <p>Cooling Capacity: 6,500-18,000 BTU/h</p> <p>Power Supply (Voltz/Hertz/Phase): 220-230/60/1</p> <p>Refrigerant: Environment Friendly</p> <p>Features: Manufacturer's Standard</p> <p>Warranty:</p> <p>Labor and Parts (1 year)</p> <p>Compressor (5 years)</p> <p>Warranty and Services:</p> <p>The winning bidder shall provide free parts, maintenance and services during the first year or operations, five (5) years warranty shall be provided for the compressor upon delivery and duly inspected. Replacement of unit is necessary if found defective.</p>	50 units	
---	--	--	----------	--

I hereby certify that the statement of compliance to the foregoing technical specifications are true and correct, otherwise, if found to be false either during bid evaluation or post-qualification, the same shall give rise to automatic disqualification of our bid.

Name of Company	Signature Over Printed Name of Authorized Representative	Date
-----------------	--	------