

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| <i>General</i> | | | |
| 1 | | As per Material specification, downspout material for sanitary is PVC which is different from Itemized breakdown of Lump sum (Stainless steel pipe (T=1.6mm)), please confirm what material to be used for the downspout as well as drainage piping. | Please use PVC for downspouts and drainage piping. Please also refer to TS 600, Clause 607.2.2 |
| 2 | | Please Provide Electrical Drawings for the Power Supply of Air- conditioning Equipments. | Considering Load Schedules, the Contractor shall submit shop drawings for approval of the Engineer. |
| 3 | | Please Provide Electrical Drawings for the Power Supply of Access Gates and Ticket Vending Machines. | The Contractor shall submit shop drawings for approval of the Engineer. |
| <i>Volume II, Part 2 – Work Requirements</i> | | | |
| 4 | CP02 Volume II, EMERGENCY STAIR (Guiguinto Station) | <u>Reference:</u> <i>Ground To Concourse level - Emergency Exit Stair Ground To Platform level - Emergency Exit Stair</i> Please Provide Emergency Lighting and Lighting Layout. | Please refer to the drawing in Book 2 of 3, Page CP02-B2-441. |
| <i>TS 600</i> | | | |
| 5 | Page TS600-78, 602.1 The Work | <u>Reference:</u> <i>The works in this section shall include all labor, material, equipment and service necessary to complete the systems identification as shown on the drawings and specified herein, including, but not limited to, the following:</i> <i>1. Valve identification. 2. Equipment identification. 3. Piping identification. 4. Duct identification. 5. Health and Safety Signage.</i> | Please refer to drawing no. NSCR-DWG-TTB-AR-3261 in Book 2 of 3, Page CP01-B4-056 for signage at Tutuban station. Similar drawing for each station/depot has also been included in the Bidding Documents. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|----------------------------------|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | There is requirement for Health and Safety Signages, please provide drawings. | |
| 6 | TS Nos 601, 614, 618, 630, 701 | <u>Reference:</u> <i>Mechanical Equipment</i> Please confirm if there will be owner supplied equipment. If there is, kindly mention. | There is no owner supplied Equipment. |
| 7 | TS Nos 601, 614, 618, 630, 701 | <u>Reference:</u> <i>Plumbing Fixtures</i> Please confirm preferred brand to be used for all plumbing fixtures. | There are no preferred brands for plumbing fixtures and equipment. The Contractor shall submit its proposal with all necessary documents to the Engineer for review/approval. |
| 8 | TS Nos 601, 614, 618, 630, 701 | <u>Reference:</u> <i>Fire Pump and Jockey Pump</i> Please confirm required brand to be used for fire pump and jockey pump. | There are no preferred brand/s for Fire Pump and Jockey Pump. The Contractor shall submit its proposal(in accordance with TS600) with all necessary documents to the Engineer for review/approval prior to installation of equipment. |
| 9 | TS Nos 601, 614, 618, 630, 701 | <u>Reference:</u> <i>Air-Conditioning Units</i> Kindly confirm preferred/required brand for all A/C units. | There are no preferred brand/s for A/C units. The Contractor shall submit its proposal (in accordance with TS600) with all necessary documents to the Engineer for review/approval prior to installation of equipment. |
| 10 | TS Nos. 601, 614, 618, 630, 701 | <u>Reference:</u> <i>Ventilation Fan</i> Kindly confirm preferred/required brand for all ventilation | There are no preferred brand/s for Ventilation Fans. The Contractor shall submit its proposal (in accordance with TS600) with all necessary documents to the Engineer for review/approval prior to installation of equipment. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|---|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | fan. | |
| 11 | TS Nos 601, 614, 618, 630, 701 | <u>Reference:</u> <i>Plumbing Fixtures</i> Please clarify if supply and installation of plumbing fixtures and electric hand dryer and liquid soap dispenser is included in our scope. | The supply and installation of plumbing fixtures, electric hand dryer and liquid soap dispenser are within the scope of the CP02 Contractor. |
| 12 | Page TS-601, 614, 618, 630, 701 | <u>Reference:</u> <i>Cistern Tank/Fire Water Tank</i> Please verify if construction of cistern tank/fire water tank is included in our scope. | The construction of cistern tank/fire water tank are within the scope of the CP02 Contractor. |
| 13 | Page TS600 – 206, TS Nos. 618, 2.4.1 Quality of waste water to be treated | Please indicate the amount of sewage per day at each station building. | For Malolos station: 17m3/day For Balagtasand Guiguinto:11m3/day |
| 14 | Page TS600 – 206, TS Nos. 618, 2.4.2 Quality of Inlet and Outlet water | The drainage standard is 618.2.4.2 of the specification, is not it | Please refer to TS 600 Clauses 618.2.4.2 and 618.2.4.3 |
| 15 | TS Nos. 618 | Please indicate the upper load (Person weight, normal vehicle weight, heavy vehicle weight etc) of the WWTP installation site | Please refer to AASHTO LRFD 3.6 Live Loads. |
| TS 700 | | | |
| 16 | CP-02 Volume 2, Drawings and Technical Specifications, Pages | <u>Reference:</u> <i>All Stations(Electrical)</i> | The Technical Specifications indicating NEMA-2 (IP-31) for Indoor Panelboards shall be followed. Also, please refer to GC Clause 1.5 for priority of documents. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|---|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | Schematic Drawings and TS 700 – 227, Power Distribution Panel | Drawings on Distribution Board Schematic diagram indicates Nema-1 Enclosure but in Technical Specifications indicates NEMA-2 (IP-31) for Indoor Panelboards. Please confirm which one to follow. | |
| 17 | CP-02 Volume 2, Drawings, Pages TS700-238 and TS700-104, Conduits | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Itemized breakdown breakdown indicates 20mmØ PVC pipe only. Can we use PVC pipes to be installed above ceiling? | Yes, the use of PVC above ceiling is allowed. The Contractor shall submit areas where these are to be used for approval of the Engineer. |
| 18 | CP-02 Volume 2, Drawings, TS700-238 and TS700-122, Conduits | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Itemized breakdown breakdown indicates 20mmØ PVC pipe only. Can we use PVC pipes to be installed above ceiling? | Yes, the use of PVC above ceiling is allowed. However, the Contractor shall submit shop drawings showing areas where these are to be used for approval of the Engineer. |
| 19 | Pages TS700-238 and TS700-113, Conduits | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Itemized breakdown breakdown indicates 20mmØ PVC pipe only. Can we use PVC pipes to be installed above ceiling? | Yes, the use of PVC above ceiling is allowed. The Contractor shall submit shop drawings showing areas where these are to be used for approval of the Engineer. |
| 20 | Page TS-700-273, Building Management System | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please provide specific list of equipment and utilities that requires control and monitoring. <u>Note: Specification states “integrates, centralizes, simplify monitoring, control, operation and management of equipment and utilities of</u> | Please refer to the drawing in Book 2 of 3, Page CP02-B2-722 which shows basic BMS Schematic Diagram and the general list of equipment and utility components to be controlled and monitored, the quantity and description would depend on each station. Also, the necessary shop drawings shall be submitted to the Engineer for approval before execution of works. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | <u>the building".</u> | |
| 21 | Page TS-700-273, Building Management System | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>Please provide specific list of equipment and utilities that requires control and monitoring. <i>Note: Specification states "integrates, centralizes, simplify monitoring, control, operation and management of equipment and utilities of the building".</i></p> | The Contractor shall submit shop drawings based on standard product for review/approval of the Engineer as per GS 100 Clause 120.4.3. |
| 22 | Page TS-700-273, Clause No. / Title Building Management System | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>Please provide specific list of equipment and utilities that requires control and monitoring. <i>Note: Specification states "integrates, centralizes, simplify monitoring, control, operation and management of equipment and utilities of the building".</i></p> | The proposal shall be submitted by the Contractor to the Engineer for its review/approval before work executions as per GS100 Clause 120.4.3. Also, shop drawings shall be submitted based on standard product for review/approval of the Engineer as per GS 100 Clause 120.4.3. |
| 23 | Page TS700-275 and CP02-B2-451, Building Management System Electrical Wiring | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>Please provide layout plan showing the cabling/wiring from BMS Equipment to Equipment Control Panels and Railway Stations SCADA</p> | The Contractor shall submit shop drawings for wiring scheme for the approval of the Engineer. |
| 24 | CP-02 Volume 2, Drawings & Technical | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> | The Contractor shall submit wiring scheme for the approval of the Engineer. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | Specifications, Pages TS700-275 and CP02-B2-722, Building Management System Electrical Wiring | Please provide layout plan showing the cabling/wiring from BMS Equipment to Equipment Control Panels and Railway Stations SCADA. | |
| 25 | TS No. 701 | <p><u>Reference:</u></p> <p><i>All Stations, Electrical</i></p> <ol style="list-style-type: none"> 1. Do you have preferred Panelboards enclosures makers? Local or imported? 2. Do you have preferred brand of Circuit breakers? 3. Do you have preferred brand of lightning protection materials? 4. Do you have preferred brand of grounding materials? 5. Do you have preferred maker of lighting fixtures enclosures/reflectors? Local or Imported? 6. Do you have preferred brand of lighting fixtures lamps? 7. Do you have preferred brand of socket outlet? 8. Do you have preferred brand of Fire Alarm Control Panel and devices? 9. Do you have preferred brand of BMS Workstations, LCD Display, Alarm Printers, Controllers, PLC and Sensors? | There are no preferred brands for electrical materials and equipment. The Contractor shall submit proposed brands and brochures for the approval of the Engineer. |
| <i>Drawings</i> | | | |
| 26 | CP-02 Volume 2, Drawings and Technical | <p><u>Reference:</u></p> <p><i>All Stations(Electrical)</i></p> | Yes, the Bidder's interpretation is correct. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|---|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | Specifications, All Electrical Systems of Work | If there are conflict between Electrical Technical Specification and Electrical Drawings, the Drawings should be followed. Is the contractor's understanding is correct? | |
| 27 | CP-02 Volume 2, Drawings and Technical Specifications, All Electrical Systems of Work | <u>Reference:</u> <i>All Stations(Electrical)</i> Is it acceptable to use locally manufactured cable trays, wiring device boxes, junction boxes and pull boxes? | There are no preferred manufacturers/brands for these items. The Contractor shall submit its proposal as per the specifications stated in TS 700 with all the necessary documents to the Engineer for review/approval. |
| 28 | CP-02 Volume 2, Drawings and Technical Specifications, All Electrical Systems of Work | <u>Reference:</u> <i>All Stations(Electrical)</i> Do Locally manufactured cable trays, wiring device boxes, junction boxes and pullboxes acceptable? | There are no preferred manufacturers/brands for these items. The Contractor shall submit its proposal as per the specifications stated in TS 700 with all the necessary documents to the Engineer for review/approval. |
| 29 | CP-02 Volume 2, Drawings and Technical Specifications, All Electrical Systems of Work | <u>Reference:</u> <i>All Stations(Electrical)</i> Please clarify. What type of wire to be used, THW or THHN? Should we use muti-core cables? If so, what limit for the size of wire for multicore and what limit for the size of wire for single core cables? | The use of THW or THHN shall depend on location.Multi/Single core cable shall depend on the type of use. The Contractor shall submit the proposal in shop drawings for the approval of the Engineer before construction. |
| 30 | CP-02 Volume 2, Drawings, General | <u>Reference:</u> <i>All Stations (Sanitary)</i> Please clarify if provision of trench/grating is included or | Provision of trench/grating is included within the scope of the CP02 contractor. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|-----------------------------------|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | excluded in our scope. | |
| 31 | CP-02 Volume 2, Drawings, General | <p><u>Reference:</u></p> <p><i>All Stations (Air Conditioning Unit)</i></p> <p>Please verify if all airconditioning unit will be precision air conditioning unit as what stated on the drawing.</p> <p>Note: It is stated on the drawing that all conventional airconditioning unit is to be changed to precision air conditioning unit.</p> | Please refer to the Equipment Schedule instead of notes on the drawings. |
| 32 | CP-02 Volume 2, Drawings, General | <p><u>Reference:</u></p> <p><i>All Stations (Fire Water Tank)</i></p> <p>Please provide the dimensions of fire water tank to all stations.</p> | The Contractor shall submit the dimensions of fire water tank for all station in shop drawing considering the capacity as 60 cu. meters. |
| 33 | CP-02 Volume 2, Drawings, General | <p><u>Reference:</u></p> <p><i>All Mainline Traction Substation (Storage Water Tank)</i></p> <p>Please provide material specification of storage water tank in all mainline traction substation.</p> | Please refer to TS 600 Clause 617. |
| 34 | CP-02 Volume 2, Drawings, General | <p><u>Reference:</u></p> <p><i>All Mainline Traction Substation (Tapping Point of Water Supply)</i></p> <p>Please verify the tapping distance from water meter assembly</p> | The exact location of tapping points shall be determined by the Contractor during construction. The Contractor shall submit shop drawing to the Engineer before execution of works. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | to existing water main supply. | |
| 35 | Lighting System | <p><u>Reference:</u></p> <p><i>All Stations(Electrical)</i></p> <p>The length of lighting fixtures as shown in the legend is 1700mm which is not standard length in Philippines. For maintenance consideration is it possible to use Philippine standard size of lighting fixture which is 1200mm?</p> | The Contractor shall propose equivalent lighting fixtures as shop drawings for the approval of the Engineer. |
| 36 | General | <p><u>Reference:</u></p> <p><i>All Mainline Traction Substation (Storage Water Tank)</i></p> <p>The contractor would like to request for Storage Water Tank material specification to be used for Mainline Traction Substation.</p> | Please refer to TS 600 Clause 617. Please also refer to the drawing in Book 2 of 3, PageCP02-B2-471. |
| 37 | CP-02 Volume 2, Drawings & Technical Specifications, Electrical Panelboards | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>Do you have required height of enclosure for Distribution Panelboards and Branch Panelboards?</p> | The Contractor shall submit shop drawings for approval of the Engineer. |
| 38 | CP-02 Volume 2, Drawings & Technical Specifications, Electrical Panelboards | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>Do you have required height of enclosure for Distribution Panelboards and Branch Panelboards?</p> | The Contractor shall submit shop drawings for approval of the Engineer. |
| 39 | CP-02 Volume 2, Drawings & | <p><u>Reference:</u></p> | The Contractor shall submit shop drawings for approval of the Engineer. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | Technical Specifications, Electrical Panelboards | <i>Guiguinto Station (Electrical)</i> Please specify the height of enclosures for Distribution panelboards and height of enclosures for Branch panelboards. | |
| 40 | CP-02 Volume 2, Drawings & Technical Specifications, Electrical Panelboards | <u>Reference:</u> <i>Main Line Traction, Substation- 7, 8 & 9 (Electrical)</i> Do you have required height of enclosure for Distribution Panelboards and Branch Panelboards? | The Contractor shall submit shop drawings for approval of the Engineer. |
| <i>Book 1 of 3</i> | | | |
| 41 | Book 1 of 3 ,Page CP02-B1-022, Drawing No. VIA00-ST-0301, Pile Layout Sheet 1, Crushed Stone for Granular Stones | According to Geotechnical Notes item no. 12, Crushed stone will be provided 200mm below Blinding concrete and Pile cap. Please advise to which pay items does this work to be included? | Please refer to item 75 of Annex "A", GBB 4. Crushed stone or compacted sand layer shall not be measured for payment as it is considered a subsidiary of the item for Blinding Concrete. |
| <i>Book 2 of 3</i> | | | |
| 42 | Book 2 of 3, Page CP02-B2-053 CP02-B2-295 CP02-B2-553, | <u>Reference:</u> <i>Electric Hand Dryers</i> Kindly provide Electrical Drawings for the power supply of Electric Hand Dryers which are shown on Architectural Drawings NSCR-DWG-BAL- AR-3272, NSCR-DWG-GUI-AR-3273 and NSCR-DWG-MAL-AR-3271. Also to other Stations if applicable. | The Contractor shall submit shop drawings and propose the circuit route for approval of the Engineer. |
| 43 | Book 2 of 3, Page CP02-B2-056, CP02- | There is a pantry sink in the architectural drawing, but there is no water line provided in the plumbing layout. Also, please | The pantry sink shall have 15mmØ water line & 75mmØ waste pipe connected to 7gpm grease trap. Electric Water Heater is not |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|---|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | B2-215, CP02-B2-298, CP02-B2-472, | confirm if Electric Water Heater is required. | required. |
| 44 | Book 2 of 3, Page CP02-B2-161 CP02-B2-185 to 187, Lighting System | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Detailed description of lighting fixtures does not match with Legend of layout plan. Which one will prevail? | Please refer to the ratings of luminaires in Book 2 of 3, Pages CP02-B2-185 to CP02-B2-187. |
| 45 | Book 2 of 3, Page CP02-B2-161 CP02-B2-185 to 187 TS700-241, Lighting System | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please specify your required lumen output for each type of LED lighting fixtures. | Please refer to the ratings of luminaires in Book 2 of 3, Pages CP02-B2-185 to CP02-B2-187 |
| 46 | Book 2 of 3, Page CP02-B2-161 CP02-B2-185 to 187 TS700-241, Lighting System | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please provide plan layout drawing for Station signboards. | The Contractor shall submit shop drawing for the approval of the Engineer. |
| 47 | Book 2 of 3, Pages CP02-B2-161, 185 to 187, 415, 440 to 442, 685, 709 to 712, Lighting System TS700-241 | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> There are conflicts on the detailed description of lighting fixtures, please clarify and confirm. | Please follow the detail description of lighting fixtures in Book 2 of 3, Pages CP02-B2-185 to CP02-B2-187. The Contractor shall submit the brochure of lighting fixtures in shop drawings for approval of the Engineer. |
| 48 | Book 2 of 3, Pages CP02-B2-164, CP02-B2-167, CP02-B2- | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> | LPC-26 shall be connected to MDB-04 ckt. No. 5 and change branch breaker 5 of MDB-04 by 50A. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|---|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | 168, CP02-B2-165, CP02-B2-170 | <p>Please clarify. The panelboard LPC-26 is not shown in Single Line Diagram but shown in Equipment Layout(NCSR-DWG-BAL-EL-5102 & 5114)</p> <p>Panel LPC-26 is missing in the single line diagram. Please confirm and clarify.</p> | |
| 49 | Book 2 of 3, Pages CP02-B2-165, CP02-B2-170, | <p><u>Reference:</u> <i>Balagtas Station (Electrical)</i></p> <p>Please provide Distribution Board schedule and Panelboard Schedule for Switchgear.</p> | Power Distribution board is not within the scope of the CP02 Contractor. However, necessary Interface shall be done between other interfacing Contractors by the CP02 Contractor. |
| 50 | Book 2 of 3, Page CP02-B2-166 | <p><u>Reference:</u> <i>Balagtas Station (Electrical)</i></p> <p>Please clarify. The Ground busbar detail indicates 1/4"(t) x 2"(w) but the Legend indicates 1/4"(t) x 4"(w). Which one will prevail?</p> | The Legend shown in Book 2 of 3, Page CP02-B2-165 shall prevail. |
| 51 | Book 2 of 3, Pages CP02-B2-167, CP02-B2-170 | <p><u>Reference:</u> <i>Balagtas Station (Electrical)</i></p> <p>Please clarify. No Switchgear in Single Line Diagram, instead MDB-01 to MDB-05. But, the equipment layout and section indicates Switchgear and MDB-01 to MDB-05. Which one will prevail?</p> | Equipment Layout and Section in Book 2 of 3, Page CP02-B2-170 shall prevail. Also, necessary Interface shall be done between other interfacing Contractors by CP02 Contractor. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| 52 | Book 2 of 3, Page CP02-B2-167, 176~181 | There are conflicts regarding the sizes and/or type of wire shown at Single Line Diagram and Distribution Board Schematic Diagram, please confirm which one to follow. | Please refer the drawing in Book 2 of 3, Page CP02-B2-190. |
| 53 | Book 2 of 3, Pages CP02-B2-167, CP02-B2-176 to CP02-B2-184 | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please provide kAIC ratings CB's for Switchgear, Distribution Boards and Panelboards. No requirements for metering? If required, please provide list and specification. | kAIC rating shall be derived based on TS 700 Clause 706.1.5. |
| 54 | Book 2 of 3, Pages CP02-B2-167, CP02-B2-182 | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please clarify about Capacitor Bank (CB, 30kVAR) at MDB-04 : How many steps of Capacitor bank is required? Requirement for Power Controller? | The Contractor to submit details in shop drawings for the approval of the Engineer. |
| 55 | Book 2 of 3, Pages CP02-B2-169, CP02-B2-171 | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please clarify/provide details of Cable tray for Lighting & Power System. Is it ladder type with cover or duct type with cover? | Please refer to the details in Book 2 of 3 Page CP02-B2-163. |
| 56 | Book 2 of 3, Pages CP02-B2-176, 177, 178, 169, 170. | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Distribution Board Schedule for Panels LPC-03, LPC-04, LPC-05, LPC-06 and LPC-23 not shown in the drawings. | LPC-03 is for Telecommunications System; LPC-04 is for Signaling; LPC-05 is for AFC and LPC-06 is for SCADA. For LPC-23 panel similar to LPC-24 in Book 2 of 3, Page CP02-B2-181. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | Please provide this information. | |
| 57 | Book 2 of 3, Page CP02-B2-178, Lighting System | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>Please clarify which one is detail B (50%) and detail (100%) since all details indicated is detail A only.</p> <p>Schematic Diagram "Detail B and C" is missing. Kindly clarify.</p> | The details shown in Book 2 of 3, Page CP02-B2-178 shall be read as Detail "A", Detail "B" and Detail "C" from left to right |
| 58 | Book 2 of 3, Page CP02-B2-179, Power Supply for ACU's | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>Please provide Power Supply plan layout for ACU's as per quantities indicated in Distribution Board Schematic.</p> | The Contractor shall submit shop drawings for the approval of the Engineer. |
| 59 | Book 2 of 3, Page CP02-B2-180, Power Supply for EF's and HRV's | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>Please provide Power Supply plan layout for EF's and HRV's as per quantities indicated in Distribution Board Schematic.</p> | The Contractor shall submit shop drawings for the approval of the Engineer. |
| 60 | Book 2 of 3, Page CP02-B2-180, Power Supply for Mechanical Equipment | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>Please provide Power Supply plan layout for Power Supply of Shutters, Potable Water Package, Fire Water Package, Waste Water Package and Jockey Pump</p> | The Contractor shall submit shop drawings for the approval of the Engineer. |
| 61 | Book 2 of 3, Page | <u>Reference:</u> | The down conductor shall be 100mm ² MDBCW. Please refer to |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|---|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | CP02-B2-180, Power Supply for Mechanical Equipment | <i>Balagtas Station (Electrical)</i> Please clarify. Technical Specification (TS 700-226) indicates minimum of 120mm ² braided Down conductor but drawing (CP02- B2-195) indicates MDBCW, which one will prevail? | the drawing in Book 2 of 3, Page CP02-B2-195. |
| 62 | Book 2 of 3, Page CP02-B2-182, Panelboard Schedule | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> The following ampere frame of circuit breakers shown has high ampere frame rating, please confirm if it is correct. Panel MDB-01, Circuit #4, 1000 AF Panel MDB-03, Circuit #'s 1 to 4 and 15, 1000 AF Panel MDB-04, Circuit # 1, 1000 AF Panel MDB-05, Circuit # 1, 1000 AF | Lower Ampere Rating shall be accepted. |
| 63 | Book 2 of 3, Page CP02-B2-182, Panelboard Schedule | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please clarify circuit # 4 of MDB-03 which is 200AT for LPC-10 but Load Schedule Main CB indicates 20AT for LPC-10. Which one will prevail? | 20AT indicated in Load Schedule Main CB in Book 2 of 3, Page CP02-B2-184 shall prevail. |
| 64 | Book 2 of 3, Pages CP02-B2-182, CP02-B2-183, CP02-B2-184, CP02-B2-167, CP02-B2-190 | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please provide panelboard Schedule for LPC-01, LPC-04, LPC-05, LPC- 06, LPC-11, LPC-12, LPC-13, LPC-14, LPC- | LPC-03 is for Telecommunications System; LPC-04 is for Signaling; LPC-05 is for AFC and LPC-06 is for SCADA. For other panels, please refer to the drawings in Book 2 of 3, Pages CP02-B2-180 and CP02-B2-181. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | 15, LPC-16, LPC-17, LPC-18, LPC-19, LPC-20, LPC-21, LPC-24, LPC-25 and LPC-26 | |
| 65 | Book 2 of 3, Page CP02-B2-184, Panelboard Schedule Panelboard Schedule | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>The following ampere frame of circuit breakers shown has high ampere frame rating, please confirm if it is correct. Panel LPC-07, Circuit #'s 3,5 &7, 1000 AF Panel LPC-08, Circuit #'s 1 & 2, 1000 AF Panel LPC-23, Circuit #'s 1 to 4 & 6, 1000 AF Panel LPC-09, Circuit #'s 17 to19,21 & 22, 1000 AF</p> | Lower Ampere Rating shall be accepted. |
| 66 | Book 2 of 3, Pages CP02-B2-187 and CP02-B2-178, Lighting System | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>Layout of Photo electric Cell not shown in the drawing, kindly provide circuit layout plan.</p> | The Contractor shall submit the scheme as shop drawings for the approval of the Engineer. |
| 67 | Book 2 of 3, Pages CP02-B2-187 and CP02-B2-178, Lighting System | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>Please indicate in the drawing for the location of Timer with Battery Pack, Selector switches and Contactors? Should we combine the controllers of 10%, 50% and 100% in one assembly?</p> | The timer with battery pack, selector and Contactor shall all be integrated to Panel LPP-01 and LPP-02. |
| 68 | Book 2 of 3, Pages CP02-B2-191 and TS 700-251 to TS | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> | Please refer to the layout in Book 2 of 3, Pages CP02-B2-192 to CP02-B2-193. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|---|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | 700-264, Fire Alarm System | What is the required standard for the system and minimum loop connection for Fire Alarm Control Panel? | |
| 69 | Book 2 of 3, Page CP02-B2-191 | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please provide circuit layout for the Power supply of Fire Alarm Control Panel. | FACP to be connected to Ckt. #11 of Panel LPC-02 in Book 2 of 3, Page CP02-B2-183. |
| 70 | Book 2 of 3, Pages CP02-B2-191, 446, 716, Fire Alarm System and TS 700-251 to TS 700-264 | <u>Reference:</u> <i>Balagtas/Malolos/Guiguinto Station (Electrical)</i> Do you have required minimum loop connection for Fire Alarm Control Panel? Please confirm if it is conventional or addressable type? | Please consider the addressable type of Fire Alarm Panel. |
| 71 | Book 2 of 3, Pages CP02-B2-191, 446, 716., Fire Alarm System | <u>Reference:</u> <i>All Stations(Electrical)</i> Fire alarm cable shown are not fire rated nor fire resistance cable. Please confirm. | Please follow the requirements in TS 700, Page TS700-255, Clause 710.4.4.1/2. The Contractor shall submit its proposal for the approval of the Engineer. |
| 72 | Book 2 of 3, Page CP02-B2-194, Lightning Protection System and TS 700-226 | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please clarify. Technical Specification (TS 700-266) indicates minimum of 120mm ² braided Down conductor but drawing (CP02- B2-195) indicates 100mm ² MDBCW, which | Down conductor shall be 100mm ² MDBCW as shown in Book 2 of 3, Page CP02-B2-195. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|---|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | one will prevail? | |
| 73 | Book 2 of 3, Page CP02-B2-194 | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>Please clarify. The lightning arrester detail indicates copper rod (9.5mmØ x 600mm) but the Legend indicates ESE type. Which one will prevail?</p> | The use of the conventional type Air Terminal as shown in the details of Book 2 of 3, Page CP02-B2-194 will prevail. |
| 74 | Book 2 of 3, Page CP02-B2-194 | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>What size of down conductor and type of wire to be used connected to Roof Steel work to earthing rods.</p> | Down conductor shall be 100mm ² MDBC Wire. |
| 75 | Book 2 of 3, Page CP02-B2-195, Lightning Protection System | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>Is it correct to interpret that the Pull box with Fiber Glass Cover and Lightning event counter shown in the drawing is the same as Grounding Terminal Box? If not, please clarify.</p> | Yes, the Bidder's interpretation is correct. |
| 76 | Book 2 of 3, Page CP02-B2-195 | <p><u>Reference:</u></p> <p><i>Balagtas Station (Electrical)</i></p> <p>If conventional type of Lightning Arrester is to be used (w/ Air Terminal 9.5mmØ x 600mm) do Lightning Event Counter still be required?</p> | Conventional type of Lightning Arrester will be used complete with Lightning event counter. |
| 77 | Book 2 of 3, Page | <u>Reference:</u> | The Contractor shall submit shop drawings showing details for the |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | CP02-B2-195 | <i>Balagtas Station (Electrical)</i> Please provide details for grounding terminal box. | approval of the Engineer. |
| 78 | Book 2 of 3, Page CP02-B2-196, Building Management System | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> BMS System Diagram indicates AC Units, Ventilation Fans, Roller Shutter Doors, CCTV Monitors, Pumps and Elevators, railway system SCADA and Fire System Control Panel. May we request to please provide specific list of equipment and utilities that requires control and monitoring. Also can you provide layout? | Please refer to the drawing in Book 2 of 3, Page CP02-B2-722 which shows basic BMS Schematic Diagram and the general list of equipment and utility components to be controlled and monitored, the quantity and description would depend on each station. Also, the necessary shop drawings shall be submitted to the Engineer for approval before execution of works. |
| 79 | Drawings & Technical Specifications, Page TS700-275 and CP02-B2-196, Building Management System Electrical Wiring | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please provide layout plan showing the cabling/wiring from BMS Equipment to Equipment Control Panels and Railway Stations SCADA. | Please refer to the drawing in Book 2 of 3, Page CP02-B2-722 which shows basic BMS Schematic Diagram and the general list of equipment and utility components to be controlled and monitored, the quantity and description would depend on each station. Also, the necessary shop drawings shall be submitted to the Engineer for approval before execution of works. |
| 80 | Book 2 of 3, Page CP02-B2-196 | <u>Reference:</u> <i>Balagtas Station (Electrical)</i> Please provide I/O points list/quantity for railway system (SCADA). | Necessary Interface shall be conducted with other interfacing Contractors by the CP02 Contractor as per GS 100 Clause 126 and Appendix-4. |
| 81 | Book 2 of 3, Page | <u>Reference:</u> | The BMS Server Panel is shown in Book 2 of 3, Page CP02-B2- |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|---|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | CP02-B2-196 | <p><i>Balagtas Station (Electrical)</i></p> <p>What panelboard name is the power supply source for BMS System Panel?</p> <p>Please provide circuit layout for the Power supply of BMS system panel.</p> | 170. The Contractor shall propose the circuit layout to the Engineer for approval. |
| 82 | Book 2 of 3, Pages CP02-B2-197, General Notes No. 15 | For one (1) year warranty coverage, do we need to include Preventive maintenance cost for equipment such as aircon, fans, pumps, filters, etc.? (For all station and substation). | Yes. All preventive maintenance cost shall be included. |
| 83 | Book 2 of 3, CP02-B2 | Electrical Layout for Pump and Tank Room was not provided. (e.g. Lighting, Convenience Outlet, Equipment Power Supply). Please provide information. | The Contractor shall submit shop drawings for the approval of the Engineer. |
| 84 | Book 2 of 3, Pages CP02-B2-205, 209, 463, 465, 732, & 737 | Base on notes 2 "All ACU units to be changed to PACW". This conflict to Equipment Schedule given, please clarify | Equipment Schedule shall be followed. |
| 85 | Book 2 of 3, Page CP02-B2-213, CP02-B2-214 | There is conflict with the size of incoming pipe for Water Closet and Urinal indicated in the Plumbing details and Schematic Diagram. Please advise which one to follow. | Please refer to the drawing in Book 2 of 3, Page CP02-B2-481 for pipe sizes in Isometry. |
| 86 | Book 2 of 3, Pages CP02-B2-214, CP02-B2-217 | Size of pipe for booster pump discharge line shown in schematic diagram is 65mm diameter but in enlarged plan it shows 50mm diameter. Please advise which one to follow. | Please use 65mmØ discharge. |
| 87 | Book 2 of 3, Page CP02-B2-225 | Please provide specifications (capacity & TDH) for the sump pump. | No sump pit/sump pump is required for Balagtas station. |
| 88 | Book 2 of 3, Page CP02-B2-225 | Please provide capacity for grease trap of Staff Pantry for Balagtas Station. | 7gpm shall be used for Grease Trap capacity. |
| 89 | Book 2 of 3, Page | <u>Reference:</u> | Each elevator sump pit shall have 1unit portable sump pump with |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | CP02-B2-225, Sanitary System | <i>Balagtas Station (Submersible Pump)</i> Please provide specifications/capacity for all submersible pump at Balagtas Station. | 0.5 HP capacity 230V/60Hz/Single Phase. The discharge will be at the nearest catch basin. |
| 90 | Book 2 of 3, Pages CP02-B2-274 and CP02-B2-435, Escalator Power Supply System | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please provide load schedule and layout plan drawings for escalators power supply. Architectural drawing CP02-B2-274 indicates 10 units of escalator but Electrical drawing CP2-132-435 indicates 6 sets units. Please confirm the quantity and provide circuit layout drawings. | The installation layout shall be submitted by the Contractor as a shop drawing for the approval of the Engineer. |
| 91 | Book 2 of 3, Page CP02-B2-274 and CP02-B2-435, Elevator Power Supply System | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please provide load schedule and layout plan drawings for elevators power supply. Architectural drawing CP02-B2-274 indicates 3 units of elevator but Electrical drawing CP2-132-435 indicates 2 sets units. Please confirm the quantity and provide circuit layout drawings. | The installation layout shall be submitted by the Contractor as a shop drawing for the approval of the Engineer. |
| 92 | Book 2 of 3, Page CP02-B2-415 CP02-B2-440 to 442 TS700-241, Lighting System | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please provide plan layout drawing for Station signboards. | The Contractor shall submit shop drawings for the approval of the Engineer. |
| 93 | Book 2 of 3, Page CP02-B2-415 | <u>Reference:</u> | The legend of layout plan in Book 2 of 3, Pages CP02-B2-440 to CP02-B2-442 shall prevail. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | CP02-B2-440 to 442, Lighting System | <i>Guiguinto Station (Electrical)</i> Detailed description of lighting fixtures does not match with Legend of layout plan. Which one will prevail? | |
| 94 | Book 2 of 3, Page CP02-B2-415 CP02-B2-440 to 442 TS700-241, Lighting System | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please specify your required lumen output for each type of LED lighting fixtures. | Please refer to the ratings of luminaires in Book 2 of 3, Pages CP02-B2-440 to CP02-B2-442. |
| 95 | Book 2 of 3, Pages CP02-B2-418, CP02-B2-419, CP02-B2-421, CP02-B2-422, CP02-B2-424 | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> 1. CP02-B2-418, 419, 421, 422 and 424: The panelboard LPG-01 is not shown in Diagram but shown in Installation Layout, please clarify For CP02-B2-421 and 422: 2. Panel LPG-01, LPG-02 and PPC-02 are missing in the Single Line and Riser Diagram, Please confirm and provide information.. 3. Please provide location for Panels LPC 24, 25 and 26. | There is no Panel LPG-01, LPG-02, PPC-02, LPC-25 and 26. |
| 96 | Book 2 of 3, Pages CP02-B2-418, CP02-B2-419, CP02-B2-421, CP02-B2-422, CP02-B2-424 | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please clarify. The panelboards LPUC-01 and LPUC-02 are not shown in | Panel LPUC-01 shall be located between Panels LPP-01 and PPC-01. Panel LPUC-02 should be located between Panels PPC-02 and LPP-02. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | Installation Layout but shown in Diagram | |
| 97 | Book 2 of 3, Pages CP02-B2-418, CP02-B2-419, CP02-B2-421, CP02-B2-422, CP02-B2-424 | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>Please clarify. The panelboard LPC-08 is not shown in Diagram but shown in Installation Layout</p> | Please refer to Book 2 of 3, Page CP02-B2-421. |
| 98 | Book 2 of 3, Page CP02-B2-420 | Panel LPUC-01, LPUC-02 and LPC-24 are missing on Station Electrical Room. Please provide location of the Panels. | Panel LPUC-01 shall be beside Panel LPC-01. Panel LPUC-02 shall be beside LPC-02 and Panel LPC-24 shall be beside LPC-23. |
| 99 | Book 2 of 3, Page CP02-B2-420 | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>Please clarify. The Ground busbar detail indicates 1/4"(t) x 2"(w) but the Legend indicates 1/4"(t) x 4"(w). Which one will prevail?</p> | The Legend in Book 2 of 3, Page CP02-B2-690 shall prevail. |
| 100 | Book 2 of 3, Pages CP02-B2-420, CP02-B2-166, CP02-B2-170, CP02-B2-692, CP02-B2-694 | <p><u>Reference:</u></p> <p><i>Balagtas, Guiguinto, Malolos Station (Electrical)</i></p> <p>Diagram shows that all detectors and horns are directly connected to Fire Alarm Annunciator Panel instead of Fire Alarm Control Panel. Please confirm and kindly give us information about the brand of equipment used in this kind of connection.</p> | The referenced page number is incorrect. |
| 101 | Book 2 of 3, Pages CP02-B2-421 and 422 | 1. Panel LPG-01, LPG-02 and PPC-02 are missing in the Single Line and Riser Diagram, Please confirm and provide information. | There is no Panel LPG-01, LPG-02, PPC-02, LPC-25 and 26. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | 2. Please provide location for Panels LPC 24, 25 and 26. | |
| 102 | Book 2 of 3, Pages CP02-B2-421 and 422 | There are conflict regarding the details of MDB-03 and MDB-04 to the Riser Diagram, Please advise which drawing to follow. | Please follow the drawing in Book 2 of 3, Page CP02-B2-422. |
| 103 | Book 2 of 3, Pages CP02-B2-421 and 430, 431, 433, 434, 435 | There are conflict regarding the sizes and/or type of wire shown on both drawings. Please advise which drawing to follow. | Please refer to the drawing in Book 2 of 3, Page CP02-B2-445 for the size of wires. |
| 104 | Book 2 of 3, Pages CP02-B2-421, CP02-B2-419, CP02-B2-420, CP02-B2-422 | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please clarify. The panelboard LPC-24 is shown in Riser Diagram but not shown in Installation Layout, Single Line Diagram and Schematic diagram. | LPC-24 shall be connected to MDB-04. |
| 105 | Book 2 of 3, Pages CP02-B2-421, CP02-B2-430 to CP02-B2-438 | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please provide kAIC ratings of CB's for Switchgear, Distribution Boards and Panelboards. No requirements for metering? If required, please provide list and specification. | kAIC rating shall be derived based on TS700 Clause 706.1.5. |
| 106 | Book 2 of 3, Pages CP02-B2-421, CP02-B2-436 | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please clarify about Capacitor Bank (CB, 30kVAR) at MDB-04: How many steps of Capacitor bank is required? Requirement | The Contractor shall submit shop drawings showing details for the approval of the Engineer. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | for Power Controller? | |
| 107 | Book 2 of 3, Pages CP02-B2-423, CP02-B2-425 | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please clarify/provide details of Cable tray for Lighting & Power System. Is it ladder type with cover or duct type with cover? | Please refer to the details in in Book 2 of 3, Page CP02-B2-417. |
| 108 | Book 2 of 3, Pages CP02-B2-430 to CP02-B2-435 | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please provide Distribution Board Schematic for MDB-01 to MDB-05, LPC-03 to LPC-06 and LPC-24 | Necessary Interface shall be conducted with other interfacing Contractors by the CP02 Contractor. |
| 109 | Book 2 of 3, Page CP02-B2-433, Power Supply for ACU's | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please provide Power Supply plan layout for ACU's as per quantities indicated in Distribution Board Schematic. | Considering the Load Schedules, the Contractor shall submit shop drawings for the approval of the Engineer. |
| 110 | Book 2 of 3, Page CP02-B2-434, Power Supply for Mechanical Equipment | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please provide Power Supply plan layout for Power Supply of EF's, Shutters, Potable Water Package, Fire Water Package, Waste Water Package and Jockey Pump | Considering the Load Schedules, the Contractor shall submit shop drawings for the approval of the Engineer. |
| 111 | Book 2 of 3, Pages CP02-B2-436 - 438 | Please provide Load Schedule for Panels LPC-03, LPC-04, LPC-05, LPC- 06, LPC-10, LPC-11, LPC-12, LPC-13, LPC- | LPC-03 is for Telecommunications System; LPC-04 is for Signaling; LPC-05 is for AFC and LPC-06 is for SCADA. For |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | 14, LPC-15, LPC-16, LPC-17 LPC-18, LPC-19, LPC-20, LPC-22, LPC-23, LPC-24, LPC-25 and LPC- 26. | other panel, refer drawings on page no. CP02-B2-433 to 435. |
| 112 | Book 2 of 3, Pages CP02-B2-436 to CP02-B2-438 | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please provide panelboard Schedule for LPC-03, LPC-04, LPC-05, LPC- 06, LPC-10 to LPC-20 and LPC-22 to LPC-24. | LPC-03 is for Telecommunications System; LPC-04 is for Signaling; LPC-05 is for AFC and LPC-06 is for SCADA. For other panels, please refer to Book 2 of 3 Pages CP02-B2-434 and CP02-B2-435. |
| 113 | Book 2 of 3, Page CP02-B2-439, Lighting System | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please clarify. Circuits No. 9 of Panelboard LPC-02 is repeated as per plan layout and no plan layout for circuit numbers 14 to 16 | Panel LPC-02 Ckt. # 14 to 16 are for signages. |
| 114 | Book 2 of 3, Page CP02-B2-439, Lighting System | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Panel LPC-02, circuit # 14, 15 and 16 are missing in circuit layout plan please clarify and confirm. | LPC-02 Ckt.#14, 15 and 16 are for signages. Please refer to Book 2 of 3, Pages CP02-B2-284 and CP02-B2-285 for the locations of signages. |
| 115 | Book 2 of 3, Page CP02-B2-440 | What is the circuit no. of six (6) interconnected lighting fixtures (3- 1x39W 1700mm & 3-1x39W, 1700mm w/ battery pack) that lies between Grid A/C and Grid 1/2? | Connect to LPC-01. |
| 116 | Book 2 of 3, Page CP02-B2-441 | What is the height of the Receptacle Outlet at the Upper Concourse Level from the finish floor line? | The height of receptacle outlet shall be 300mm AFFL unless otherwise stated. |
| 117 | Book 2 of 3, Page CP02-B2-441, Lighting System | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> | 1. The 5-Smart Bay Lighting Fixtures shall be connected to Ckt. #15 of Panel LPUC-02. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | <p>1. What is the circuit no. of five (5) interconnected lighting fixtures (5- pendant type (suspended) smart bay lighting fixture with 1 200w LED lamp) that lies between Grid C/D and Grid 10/12?</p> <p>2. Please clarify. Circuits Nos. 4, 5, 10 of Panelboard LPC-01 are repeated as per plan layout.</p> | <p>2. Please refer to Book 2 of 3, Page CP02-B2-440.</p> |
| 118 | Book 2 of 3, Page CP02-B2-446 CP02-B2-447 CP02-B2-448, Fire Alarm System | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>Please clarify. Schematic Diagram does not match with Plan Layouts. Which one shall prevail?</p> | The Plan Layout in Book 2 of 3 Pages CP02-B2-447 and CP02-B2-448 shall prevail. |
| 119 | Book 2 of 3, Page CP02-B2-446 and TS 700-251 to TS 700-264, Fire Alarm System | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>What is the required standard for the system and minimum loop connection for Fire Alarm Control Panel?</p> | Please refer to the drawings in Book 2 of 3 Pages CP02-B2-447 and CP02-B2-448. |
| 120 | Book 2 of 3, Pages CP02-B2-446 CP02-B2-447, CP02-B2-448 | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>Please provide circuit layout for the Power supply of Fire Alarm Control Panel.</p> | FACP to be connected to Ckt. #16 of Panel LPC-02 in Book 2 of 3, Page CP02-B2-437. |
| 121 | Book 2 of 3, Pages CP02-B2-446 CP02-B2-447, CP02-B2-448 | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> | Fire Alarm is not provided in Ground Floor Water Tank and Pump Room. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | Please provide layout drawing for Ground Floor Water Tank and Pump Room. Note: Smoke Detector and FA Annunciator Panel are reflected in FA Schematic Diagram. | |
| 122 | Book 2 of 3, Pages CP02-B2-446, 447, 228., Fire Alarm System | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Fire Alarm Schematic Diagram does not match with circuit layout plans please confirm which one to follow. | Please follow the FA Circuit Layout in Book 2 of 3, Pages CP02-B2-447 and CP02-B2-448. |
| 123 | Book 2 of 3, Pages CP02-B2-446, 447, 448. | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please provide Fire Alarm circuit layout drawings for Ground floor Water tank and Pump room. | Fire Alarm is not provided in Ground Floor Water Tank and Pump Room. |
| 124 | Book 2 of 3, Page CP02-B2-449 and TS 700-226, Lightning Protection System | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please clarify. Technical Specification (TS 700-266) indicates minimum of 120mm ² braided Down conductor but drawing (CP02- B2-450) indicates 100mm ² MDBCW, which one will prevail? | The down conductor shall be 100mm ² MDBCW as shown in Book 2 of 3, Page CP02-B2-450. |
| 125 | Book 2 of 3, Page CP02-B2-449 | <u>Reference:</u> <i>Guiguinto Station (Electrical)</i> Please clarify. The lightning arrester detail indicates copper rod (9.5mmØ x 600mm) but the Legend indicates ESE type. Which one will | The use of the conventional type Air Terminal as shown in the detail in Book 2 of 3, Page CP02-B2-449 will prevail. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | prevail? | |
| 126 | Book 2 of 3, Page CP02-B2-449, CP02-B2-450 | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>If conventional type of Lightning Arrester is to be used (w/ Air Terminal 9.5mmØ x 600mm) do Lightning Event Counter still be required?</p> | Conventional type of Lightning Arrester will be used complete with Lightning event counter. |
| 127 | Book 2 of 3, Page CP02-B2-449 | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>What size of down conductor and type of wire to be used connected to Roof Steel work to earthing rods.</p> | The down conductor shall be 100mm ² MDBC Wire. |
| 128 | Book 2 of 3, Pages CP02-B2-450, Lightning Protection System | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>Is it correct to interpret that the Pull box with Fiber Glass Cover and Lightning event counter shown in the drawing is the same as Grounding Terminal Box? If not, please clarify.</p> | Yes, the Bidder's interpretation is correct. |
| 129 | Book 2 of 3, Pages CP02-B2-450 | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>Please provide details for grounding terminal box.</p> | The Contractor shall submit the details as shop drawings for the approval of the Engineer. |
| 130 | Book 2 of 3, Page CP02-B2-451, Building Management System | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> | The Contractor shall submit shop drawings based on standard product for review/approval of the Engineer as per GS 100 Clause 120.4.3. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|---|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | BMS System Diagram indicates AC Units, Ventilation Fans, Roller Shutter Doors, CCTV Monitors, Pumps and Elevators, railway system SCADA and Fire System Control Panel. May we request to please provide specific list of equipment and utilities that requires control and monitoring. Also can you provide layout? | |
| 131 | Book 2 of 3, Pages CP02-B2-451 | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>Please provide I/O points list/quantity for railway system (SCADA).</p> | Quantity of I/O points should be as required by SCADA provider to make the system operational. |
| 132 | Book 2 of 3, Pages CP02-B2-451 | <p><u>Reference:</u></p> <p><i>Guiguinto Station (Electrical)</i></p> <p>What panelboard name is the power supply source for BMS System Panel?</p> <p>Please provide circuit layout for the Power supply of BMS system panel.</p> | BMS Server Panel as shown in Book 2 of 3, Page CP02-B2-419. The Contractor shall propose circuit layout to the Engineer for approval. |
| 133 | Book 2 of 3, Pages CP02-B2-469 and 483 | <p>Please provide sanitary layout for G.A.D. room.</p> <p>There are conflict in the connection of urinal drain pipe as shown in the drawings, please confirm which one to follow.</p> | <p>Please ignore toilet fixtures inside G.A.D. room. Please refer to architectural trade for the details of G.A.D. room.</p> <p>All urinal drain pipes are connected to soil pipe (SP) together with water closet drain pipes as reflected in Toilet Blow-up Plan. There are no conflicts as far as the drawing is concerned.</p> |
| 134 | Book 2 of 3, Pages CP02-B2-476, CP02-B2-481 | There is conflict in pipe size and pipe type between Gutter Drain detail and schematic diagram. Please specify which is to follow. | Please refer to the drawing in Book 2 of 3, Page CP02-B2-481 for gutter drain sizes in Isometry. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| 135 | Book 2 of 3, Page CP02-B2-494 | No fire protection system in Station Electrical Room. Please confirm. | There is no fire protection system in Station Electrical Room. However, fire extinguisher/fire hose cabinet are provided. |
| 136 | Book 2 of 3, Page CP02-B2-685 CP02-B2-709 to 712, Lighting System | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please provide plan layout drawing for Station signboards. | The Contractor shall submit shop drawings for the approval of the Engineer. |
| 137 | Book 2 of 3, Pages CP02-B2-685 CP02-B2-709 to 712, Lighting System | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Detailed description of lighting fixtures does not match with Legend of layout plan. Which one will prevail? | The detailed description of lighting fixtures in the Legend in Book 2 of 3, Pages CP02-B2-709 to CP02-B2-712 shall prevail. |
| 138 | Book 2 of 3, Pages CP02-B2-685 CP02-B2-709 to 712 TS700-241, Lighting System | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please specify your required lumen output for each type of LED lighting fixtures. | Please refer to the ratings of luminaires in Book 2 of 3, Pages CP02-B2-709 to CP02-B2-712. |
| 139 | Book 2 of 3, Pages CP02-B2-690, CP02-B2-694 | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please provide Distribution Board schedule and Panelboard Schedule for Switchgear. | Necessary Interface shall be conducted with other interfacing Contractors by the CP02 Contractor. |
| 140 | Book 2 of 3, Page CP02-B2-690 | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please clarify. | The Legend in Book 2 of 3, Page CP02-B2-690 shall prevail. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | The Ground busbar detail indicates 1/4"(t) x 2"(w) but the Legend indicates 1/4"(t) x 4"(w). Which one will prevail? | |
| 141 | Book 2 of 3, Pages CP02-B2-691 and CP02-B2-706, Panelboard Schedule & Single Line Diagram | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please provide Load Schedule for Panel MDB-04. Panel MDB-05 shown in load schedule but not shown in single line diagram. Please confirm and clarify. | MDB-05 shown in Book 2 of 3, Page CP02-B2-706 shall be MDB-04. |
| 142 | Book 2 of 3, Pages CP02-B2 691 and 715 | THHN was shown in drawing number NSCR-DWG-MAL-EL-5161 but THWN was shown the single line diagram NCR-DWG-MAL-EL-5111, please advise which one to follow. | The drawing in Book 2 of 3, Page CP02-B2-715 shall be followed. |
| 143 | Book 2 of 3, Pages CP02-B2-691, CP02-B2-706 | <u>Reference:</u> <i>Malolos Station (Electrical)</i> The Single Line Diagram of MDB-03 and MDB-05 are not the same with Panelboard Load Schedule. Please confirm which one to follow. | The Load Schedule in Book 2 of 3, Page no. CP02-B2-706 should be followed. |
| 144 | Book 2 of 3, Pages CP02-B2-691, CP02-B2-693, CP02-B2-694 | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please provide location of Panels LPC-03, LPC-04, LPC-05 and LPC-06. | All these panels are located inside the Electrical Room of the stations. However, necessary Interface shall be conducted by the CP02 Contractor with other interfacing Contractors/System Contractors as per GS 100, Clause 126 and Appendix 4. |
| 145 | Book 2 of 3, Pages CP02-B2-691, CP02-B2-700 to CP02-B2-708 | <u>Reference:</u> <i>Malolos Station (Electrical)</i> | kAIC rating shall be derived based on TS700 Clause 706.1.5. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | Please provide kAIC ratings of CB's for Switchgear, Distribution Boards and Panelboards. No requirements for metering? If required, please provide list and specification. | |
| 146 | Book 2 of 3, Pages CP02-B2-691, CP02-B2-694 | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>Please clarify. No Switchgear in Single Line Diagram, instead MDB-01 to MDB-04. But, the equipment layout and section indicates Switchgear and MDB-01 to MDB-04. Which one will prevail?</p> | The equipment layout in Book 2 of 3, Page CP02-B2-694 shall prevail. |
| 147 | Book 2 of 3, Pages CP02-B2-693, CP02-B2-695 | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>Please clarify/provide details of Cable tray for Lighting & Power System. Is it ladder type with cover or duct type with cover?</p> | Please refer to the details in Book 2 of 3, Page CP02-B2-687. |
| 148 | Book 2 of 3, Page CP02-B2-700-705 | <ol style="list-style-type: none"> 1. Sizes, Type of Wires and number of core are conflict in wire schedule and panel schedule. Please confirm which one to follow. 2. Conflicting grounding wire sizes in wire schedule and panel schedule, please confirm which one to follow. 3. The number of circuits shown in the drawing are not the same in the panel board load schedule. Please advise which one to follow. | <ol style="list-style-type: none"> 1. For the sizes of wires, please refer to Book 2 of 3, Page CP02-B2-715. 2. The grounding lead from the panel grounding terminal shall be 8.0mm² TW as shown in Book 2 of 3, Page CP02-B2-705. 3. Consider the number of circuits shown in the drawings in Book 2 of 3, Pages CP02-B2-700 to CP02-B2-705. |
| 149 | Book 2 of 3, Pages CP02-B2-700 to CP02-B2-708, CP02- | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> | LPC-03 is for Telecommunications System; LPC-04 is for Signaling; LPC-05 is for AFC and LPC-06 is for SCADA. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|---|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | B2-691 | Please provide Distribution Board Schedule for LPC-03, LPC-04, LPC-05 and LPC-06. | |
| 150 | Book 2 of 3, Page CP02-B2-703, Power Supply for ACU's | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please provide Power Supply plan layout for ACU's as per quantities indicated in Distribution Board Schematic. | The Contractor shall submit shop drawings for approval of the Engineer. |
| 151 | Book 2 of 3, Page CP02-B2-704, Power Supply for Mechanical Equipment | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please provide Power Supply plan layout for Power Supply of EF's, Shutters, Potable Water Package, Fire Water Package, Waste Water Package and Jockey Pump | The Contractor shall submit shop drawings for approval of the Engineer. |
| 152 | Book 2 of 3, Page CP02-B2-704, Power Supply for Door Shutter | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please provide layout plan and load schedule for the power supply of Door Shutters. The quantity of Door Shutter shown in Architectural drawings does not match with Electrical drawings. | The Contractor shall submit shop drawing for the approval of the Engineer. |
| 153 | Book 2 of 3, Pages CP02-B2-705 | There are conflicts on the number of poles of Main Circuit Breaker shown on wire schedule and panel board schedule. Please confirm which one to follow. | Please use 4P main breakers as shown in the Load Schedule. |
| 154 | Book 2 of 3, Pages CP02-B2-706 to CP02-B2-708, CP02- | <u>Reference:</u> <i>Malolos Station (Electrical)</i> | LPC-03 is for Telecommunications System; LPC-04 is for Signaling; LPC-05 is for AFC and LPC-06 is for SCADA. For other panels, please refer to Book 2 of 3, Pages CP02-B2-705 and |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | B2-715, CP02-B2-691 | Please provide panelboard Schedule for LPC-03, LPC-04, LPC-05, LPC- 06, LPC-11, LPC-12, LPC-13, LPC-14, LPC-15, LPC-16, LPC-17, LPC-18, LPC-19, LPC-20, LPC-21, LPC-22 and LPC-23 | CP02-B2-706. |
| 155 | Book 2 of 3, Pages CP02-B2-707 and CP02-B2-711, Panelboard Schedule | <u>Reference:</u> <i>Malolos Station (Electrical)</i> LPUC-02 Load Schedule circuit description does not match with Plan Layout. Please clarify. | Please use LPUC-02 Load Schedule. |
| 156 | Book 2 of 3, Page CP02-B2-708 | Please provide Load schedule for Panels LPC-11, LPC-23 and Panel LPC- 03-LPC-06. | LPC-03 is for Telecommunications System; LPC-04 is for Signaling; LPC-05 is for AFC and LPC-06 is for SCADA. For LPC-11 and 23 refer to page no. CP02-B2-704 and 705. |
| 157 | Book 2 of 3, Pages CP02-B2-709 and CP02-B2-711, Lighting System | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Circuits Nos. 9, 10, 11 of Panelboard LPC-02 are missing in Plan Layout as compared to Load Schedule. Please provide drawing. Otherwise, Load schedule shall prevail. | The Load Schedule shall prevail. |
| 158 | Book 2 of 3, Page CP02-B2-709 | <u>Reference:</u> <i>Malolos Station (Electrical)</i> 1. There are no Panel LPG-01 and PPC-02 indicated in the panel board load schedule and its location, but it has a circuit homerun shown on the drawing (NSCR-DWG-MAL-EL-5151,5152). Please confirm. 2. There are missing circuit homerun for receptacle layout. | The missing homerun for the receptacles shall be connected to Panel PPC-01. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|---|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | Please confirm and provide missing information's. | |
| 159 | Book 2 of 3, Page CP02-B2-709 | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>Please clarify. The panelboards LPG-01 & LPG-02 are shown in plan but not shown in Single Line Diagram and Load Schedule.</p> | Connect Panel LPG-01 with 100AT Main and 12 – 20AT, 1P branches to Ckt. #6 of MDB-01 and Panel LPG-02 with Main 60AT and 8 – 20AT, 1P Branches to Ckt. #4 of MDB-02. |
| 160 | Book 2 of 3, Page CP02-B2-710, Lighting System | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>Please clarify. The Layout indicates Suspended Lighting fixture, 1700mm, 2 x 39W but Legend indicates 1 x39W only. Which one will prevail?</p> | The number of fixture lamps indicated in the layout shall prevail. |
| 161 | Book 2 of 3, Page CP02-B2-710, Lighting System | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>No Panelboard PP-02 but the plan layout indicates connected circuit #'s 2 to 5. Please clarify where/what panelboard to connect this circuit #'s 2 to 5.</p> | The ckts# 2 to 5 for receptacles shall be connected to PPC-01. |
| 162 | Book 2 of 3, Page CP02-B2-711 | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>Please provide the missing wiring layout for the lighting system. Particular on 2-20W LED Lighting Fixture.</p> | Connect 4-2x20W LED L/F to ckt. # 4 and 4-2x20W LED L/F to ckt#6 of Panel LPUC-02. |
| 163 | Book 2 of 3, Page | Quantity of smoke detector conflicts from layout compared to | Please follow the quantity in the layout plan in Book 2 of 3, Page |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | CP02 -B2-716-717 | the Fire Alarm schematic Diagram. Please confirm which one to follow. | CP02-B2-717. |
| 164 | Book 2 of 3, CP02-B2-716 and TS 700-251 to TS 700-264, Fire Alarm System | <u>Reference:</u> <i>Malolos Station (Electrical)</i> What is the required standard for the system and minimum loop connection for Fire Alarm Control Panel? | Please refer to the layout in Book 2 of 3, Pages CP02-B2-717 to CP02-B2-719. |
| 165 | Book 2 of 3, Page CP02-B2-716 | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please provide circuit layout for the Power supply of Fire Alarm Control Panel. | FACP to be connected to Ckt. #8 of Panel LPC-01 in Book 2 of 3, Page CP02-B2-707. |
| 166 | Book 2 of 3, Page CP02-B2-720 and TS 700-226, Lightning Protection System | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please clarify. Technical Specification (TS 700-266) indicates minimum of 120mm ² braided Down conductor but drawing (CP02- B2-721) indicates 100mm ² MDBCW, which one will prevail? | The drawing in Book 2 of 3, Page CP02-B2-721 shall prevail. |
| 167 | Book 2 of 3, Page CP02-B2-720 | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please clarify. The lightning arrester detail indicates copper rod (9.5mmØ x 600mm) but the Legend indicates ESE type. Which one will prevail? | The use of the conventional type Air Terminal as shown in the details in Book 2 of 3, Page CP02-B2-720 will prevail. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| 168 | Book 2 of 3, Page CP02-B2-720 | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>What size of down conductor and type of wire to be used connected to Roof Steel work to earthing rods.</p> | The down conductor shall be 100mm ² MDBC Wire. |
| 169 | Book 2 of 3, Page CP02-B2-721, Lightning Protection System | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>Is it correct to interpret that the Pull box with Fiber Glass Cover and Lightning event counter shown in the drawing is the same as Grounding Terminal Box? If not, please clarify.</p> | Yes, the Bidder's interpretation is correct. |
| 170 | Book 2 of 3, Page CP02-B2-721 | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>If conventional type of Lightning Arrester is to be used (w/ Air Terminal 9.5mmØ x 600mm) do Lightning Event Counter still be required?</p> | Conventional type of Lightning Arrester will be used complete with Lightning event counter. |
| 171 | Book 2 of 3, Page CP02-B2-721 | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>Please provide details for grounding terminal box.</p> | The Contractor shall submit the details as shop drawings for the approval of the Engineer. |
| 172 | Book 2 of 3, Page CP02-B2-722, Building Management System | <p><u>Reference:</u></p> <p><i>Malolos Station (Electrical)</i></p> <p>BMS System Diagram indicates AC Units, Ventilation Fans,</p> | The Contractor shall submit shop drawings based on standard product for review/approval of the Engineer as per GS 100 Clause 120.4.3. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|-------------------------------------|--|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | Roller Shutter Doors, CCTV Monitors, Pumps and Elevators, railway system SCADA and Fire System Control Panel. May we request to please provide specific list of equipment and utilities that requires control and monitoring. Also can you provide layout? | |
| 173 | Book 2 of 3, Page CP02-B2-722 | <u>Reference:</u> <i>Malolos Station (Electrical)</i> Please provide I/O points list/quantity for railway system (SCADA). | The quantity of I/O points should be as required by SCADA provider to make the system operational. |
| 174 | Book 2 of 3, Page CP02-B2-722 | <u>Reference:</u> <i>Malolos Station (Electrical)</i> What panelboard name is the power supply source for BMS System Panel? Please provide circuit layout for the Power supply of BMS system panel. | BMS Server Panel as shown in Book 2 of 3, Page CP02-B2-689. The Contractor shall propose circuit layout to the Engineer for approval. |
| 175 | Book 2 of 3, Page CP02-B2-726 | V4 STEEL BRACKET ANTI COROSSIVE is described in outdoor unit installation detail, is the material SUS304? | For equipment brackets and supports, mild steel metal shall be used. |
| 176 | Book 2 of 3, Page CP02-B2-730 & 738 | In Distribution Board Room and UPS Room, outside Air Diffuser with Fire Damper are shown without Ventilating Fan equipments. Please confirm. | Ventilating Fan shall be provided. |
| 177 | Book 2 of 3, Page CP02-B2-732 | Base on the Note 1. It is stated that "Provide Shut-off Dampers on all intake and Exhaust Louver". Is this applicable on all rooms such as Comm Equipment room, Com m UPS room, Ser room, Sur room, AFC room and AFC UPS room? | Yes, the Bidder's understanding is correct. |
| 178 | Page CP02-B2-736 | For A/C outdoor units, there are no access for maintenance | All A/C outdoor units are provided on top of Room slab and can |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|---|--|--|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | shown. Please confirm. | be accessible. |
| 179 | Book 2 of 3, Page CP02-B2-754, Drawing No. NSCR-DWG-MAL-SN-6104, Malolos Station Sanitary - Layout Ground Level, Malolos Station (Sanitary Station) | There is no drawing for Oil Interceptor in Malolos Station. Please confirm and if required kindly provide drawings. | Oil interceptors are required in Malolos Station and it should be located on ground level outside gridline A/10 (serving drain lines from Station's Electrical Room and Railway Electrical rooms at concourse level) and another outside gridline A/15 (serving COMM equipment and UPS rooms at ground level). Please refer to Book 2 of 3, Page CP02-B2-482 for oil interceptor detail. All oil interceptor will connect to nearest catch basin (please see Book 2 of 3, Page CP02-B2-502). |
| <i>Book 3 of 3</i> | | | |
| 180 | Book 3 of 3, Page CP02-B3-041 and CP02-B3-047, Lighting System | <u>Reference:</u> <i>Main Line Traction, Substation- 7 (Electrical)</i> Detailed description of lighting fixtures does not match with Legend of layout plan. Which one will prevail? Please specify Lumen output for each lamp type. | The legend in the layout plan in Book 3 of 3, Page CP02-B3-047 shall prevail. |
| 181 | Book 3 of 3, Page CP02-B3-045, CP02-B3-109, CP02-B3-174 | <u>Reference:</u> <i>Main Line Traction, Substation- 7, 8 & 9. (Electrical)</i> Please provide feeder line tapping point of Panel LPC-01. | Please refer to Drawing No. NSCR-DWG-MTS7-EL-5102 in Book 2 of 3, Page CP02-B3-044 for the location of AC Low Voltage Panel. |
| 182 | Book 3 of 3, Page CP02-B3-105 and CP02-B3-111, Lighting System | <u>Reference:</u> <i>Main Line Traction, Substation- 8 (Electrical)</i> Detailed description of lighting fixtures does not match with Legend of layout plan. Which one will prevail? Please | The legend in the layout plan in Book 3 of 3, Page CP02-B3-111 shall prevail. |

| North – South Commuter Railway (NSCR) Project (Malolos – Tutuban) Package CP02: Elevated Structures and 3 Stations | | | |
|---|--|---|---|
| ITEM NO. | REFERENCE CLAUSE/ SECTION | CLARIFICATION REQUEST | RESPONSE |
| | | specify Lumen output for each lamp type. | |
| 183 | Book 3 of 3, Page CP02-B3-170 and CP02-B3-176, Lighting System | <p><u>Reference:</u></p> <p><i>Main Line Traction, Substation- 9 (Electrical)</i></p> <p>Detailed description of lighting fixtures does not match with Legend of layout plan. Which one will prevail? Please specify Lumen output for each lamp type.</p> | The legend in the layout plan in Book 3 of 3, Page CP02-B3-176 shall prevail. |