

Room Number	Room Designation	Ceiling Finish
512	Duct Space 2	Please refer to drawing CP01-B8-239 (Schedule of Finishes) which refers to ceiling finish as painted soffit of slab/beam and same interpreted in drawing numbers CP01-B8-211 and CP01-B8-212.
513	Duct Space 1	
102	Corridor	Please use 600 x 600 Lay-in Metal Ceiling, Please refer to TS 544 with particular attention to TS 544.1.1 clause b.i
232	Elevator Hall A 2F	
200A	Stairs 1-GF	There are two types of ceiling finish for the Stair 1 & 2. Please refer to the Reflected Ceiling Plan in Section VI, 3 Drawings, Book 8 of 11, Pages CP01-B8-221 to CP01-B8-226.
200B	Stairs 2-GF	
300A	Stairs 1-3F	
300B	Stairs 2-3F	
400A	Stairs 1-4F	
400B	Stairs 2-4F	
500A	Stairs 1-5F	
500B	Stairs 2-5F	
310	Storage	12mm Thk Moisture Resistant Gypsum Board on GA#24 Metal Frames
324	Female Locker Room	600x600x12mm Thk. Acoustic Ceiling Boards with Foil Backing. Please refer to TS 545 with particular attention to TS 545.1.6
327	Male Locker Room	
330	Electric Mngt. Div. Lounge	
336	Stock Room	12mm Thk Moisture Resistant Gypsum Board on GA#24 Metal Frames
112	Elevator Hall A-GF	Please use 600 x 600 Lay-in Metal Ceiling, Please refer to TS 544 with particular attention to TS 544.1.1 clause b.i
131	Reception Counter	600x600 Cell Type Metal Ceiling. Please refer to TS 544 with particular attention to TS 544.1.1 clause b.i
222	Meeting Space	Please use 600 x 600 Lay-in Metal Ceiling, Please refer to TS 544 with particular attention to TS 544.1.1 clause b.i
323	Elevator Hall A-3F	
428	Elevator Hall A-4F	
103	F-Scada	600x600x12mm Thk. Acoustic Ceiling Boards with Foil Backing. Please refer to TS 545 with particular attention to TS 545.1.6
113	Security	
121	AFC Room	
122	P-Scada	
209	Stock Room	
211	Crew Mngt. Div. Manager Room	
212	Crew Mngt. Room	
214	Crew Mngt. Div. Lounge	

Room Number	Room Designation	Ceiling Finish
215	Female Locker Room	
219	Male Locker Room	
223	Bedroom Male	
224	Bedroom Female	
225	Canteen	
226	Janitor Room	
227	Linen Room	
229	Pantry 1	
313	Conference Room 1-3	
315	Facility Mngt. Div. Mngr. Room	
316	Facility Mngt. Div. . Room	
319	Facility Mngt. Lounge	
332	Electric Mngt. Room	
409	Conference Room	
410	Training Room	
411	Stock Room	
413	OCC Div. Manager Room	
414	OCC Assistance Room	
415	Upper Part of Operation Control Center	
418	Vestibule	
419	OCC Lounge	
420	OCC Female Locker Room	
423	Male Locker Room	
510	Meeting Room 4	600x600x12mm Thk. Acoustic Ceiling Boards with Foil Backing. Please refer to TS 545 with particular attention to TS 545.1.6
511	Meeting Room 2	
514	Meeting Room 3	
515	Meeting Room 1	